

Kentec Electronics Ltd.

# Declaration of Performance

According to Construction Products Regulation EU N° 305/2011



Certificate Reference N° 00007

**Product identification:**

FIRE ALARM POWER SUPPLY EQUIPMENT

**Type:**

K25250 and KD25250 series

**Intended use:**

Fire detection and fire alarm systems installed in and around buildings

**Manufacturer:**

Kentec Electronics Limited  
Units 25-27 Fawkes Avenue  
Questor  
Dartford  
Kent  
DA1 1JQ  
UK

**Authorised representative:**

Not applicable

**System of assessment and verification of constancy of performance.**

System 1

**BSI**

Performed type testing and the initial inspection of the manufacturing plant and of factory production control with continuous surveillance, assessment and approval of the factory production control under system 1 and issued following certificate of constancy of performance:

0086-CPD-553773

All requirements including all Essential Characteristics and the corresponding performances for the intended use or uses have been determined as described in the hEN mentioned in the table below.

Essential characteristics	Performance	Harmonized technical specification
Operational reliability	Passed	EN 54-4:1997 + A2:2006 Art.: 4, 5, 6, 7 and 8
Durability of operational reliability, Temperature resistance	Passed	EN 54-4:1997 + A2:2006 Art.: 9.5
Durability of operational reliability, Vibration resistance	Passed	EN 54-4:1997 + A2:2006 Art.: 9.7, 9.8 and 9.15
Durability of operational reliability, Electrical stability	Passed	EN 54-4:1997 + A2:2006 Art.: 9.9 to 9.13
Performance of power supply	Passed	EN 54-4:1997 + A2:2006 Art.: 4, 5, 6
Durability of operational reliability, humidity resistance	Passed	EN 54-4:1997 + A2:2006 Art.: 9.6, 9.14

The performance of the product identified above is in conformity with the set of declared performance/s.

This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:




Robert Jefferys

Director

Dartford

17/06/14



Kentec Electronics Ltd.

# Declaration of Performance

According to Construction Products Regulation EU N° 305/2011



Certificate Reference N° 00006

**Product identification:**

FIRE ALARM POWER SUPPLY EQUIPMENT

**Type:**

K25400 and KD25400 series

**Intended use:**

Fire detection and fire alarm systems installed in and around buildings

**Manufacturer:**

Kentec Electronics Limited  
Units 25-27 Fawkes Avenue  
Questor  
Dartford  
Kent  
DA1 1JQ  
UK

**Authorised representative:**

Not applicable

**System of assessment and verification of constancy of performance.**

System 1

**BSI**

Performed type testing and the initial inspection of the manufacturing plant and of factory production control with continuous surveillance, assessment and approval of the factory production control under system 1 and issued following certificate of constancy of performance:

0086-CPD-553773

All requirements including all Essential Characteristics and the corresponding performances for the intended use or uses have been determined as described in the hEN mentioned in the table below.

Essential characteristics	Performance	Harmonized technical specification
Operational reliability	Passed	EN 54-4:1997 + A2:2006 Art.: 4, 5, 6, 7 and 8
Durability of operational reliability, Temperature resistance	Passed	EN 54-4:1997 + A2:2006 Art.: 9.5
Durability of operational reliability, Vibration resistance	Passed	EN 54-4:1997 + A2:2006 Art.: 9.7, 9.8 and 9.15
Durability of operational reliability, Electrical stability	Passed	EN 54-4:1997 + A2:2006 Art.: 9.9 to 9.13
Performance of power supply	Passed	EN 54-4:1997 + A2:2006 Art.: 4, 5, 6
Durability of operational reliability, humidity resistance	Passed	EN 54-4:1997 + A2:2006 Art.: 9.6, 9.14

The performance of the product identified above is in conformity with the set of declared performance/s.

This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:




Robert Jefferys

Director

Dartford

17/06/14



Kentec Electronics Ltd.

# Declaration of Performance

According to Construction Products Regulation EU N° 305/2011



Certificate Reference N° 00008

**Product identification:**

POWER SUPPLY

**Type:**

K25800 and KD25800 series

**Intended use:**

Fire detection and fire alarm systems installed in and around buildings

**Manufacturer:**

Kentec Electronics Limited  
Units 25-27 Fawkes Avenue  
Questor  
Dartford  
Kent  
DA1 1JQ  
UK

**Authorised representative:**

Not applicable

**System of assessment and verification of constancy of performance.**

System 1

**BRE Global Ltd 0832**

Performed type testing and the initial inspection of the manufacturing plant and of factory production control with continuous surveillance, assessment and approval of the factory production control under system 1 and issued following certificates of constancy of performance:

- 0832-CPR-F0315
- 0832-CPR-F0315
- 0832-CPR-F0316
- 0832-CPR-F0316
- 0832-CPR-F0317
- 0832-CPR-F0317
- 0832-CPR-F0318
- 0832-CPR-F0318

All requirements including all Essential Characteristics and the corresponding performances for the intended use or uses have been determined as described in the hEN mentioned in the table below.

Essential characteristics	Performance	Harmonized technical specification
Operational reliability	Passed	EN 54-4:1997 + A2:2006 Art.: 4, 5, 6, 7 and 8
Durability of operational reliability, Temperature resistance	Passed	EN 54-4:1997 + A2:2006 Art.: 9.5
Durability of operational reliability, Vibration resistance	Passed	EN 54-4:1997 + A2:2006 Art.: 9.7, 9.8 and 9.15
Durability of operational reliability, Electrical stability	Passed	EN 54-4:1997 + A2:2006 Art.: 9.9 to 9.13
Performance of power supply	Passed	EN 54-4:1997 + A2:2006 Art.: 4, 5, 6
Durability of operational reliability, humidity resistance	Passed	EN 54-4:1997 + A2:2006 Art.: 9.6, 9.14

The performance of the product identified above is in conformity with the set of declared performance/s.

This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:



Robert Jefferys

Director

Dartford

17/06/14